

SCHEDULE 40 CONDUIT

Rigid Nonmetallic Conduit Above Ground and Underground



Intertek

Queen City Plastics Schedule 40 conduit is produced from Electrical Testing Labs (ETL) 90 Degree C approved, Queen City Plastics 8121B rigid PVC compound. The inherent properties of this PVC compound render the product ideal for above and below ground utilization as described in Article 352 of the National Electrical Code (NEC).

Queen City Plastics conduit is manufactured to and complies with the following specifications and should be installed in accordance with Article 352 of the National Electrical Code (NEC):

Underwriters Laboratories, Inc. (UL)

UL-651

National Electrical Manufacturers Association (NEMA) TC-2

Federal Specification

WC-1094-A

SIZE	CATALOG NUMBER	O.D.	MIN WALL	WGT 100'	BUNDLE-SIZE	PALLET QUANTITY 10'	STANDARD QUANTITY 20'
1/2"	110053X	.840	.109	17	100'	6000'	12,000'
3/4"	110083X	1.050	.113	23	100'	4400'	8800'
1"	110103X	1.315	.133	34	100'	3600'	7200'
1-1/4"	110133X	1.660	.140	46	50'	3300'	6600'
1-1/2"	110153X	1.900	.145	55	50'	2250'	4500'
2"	110203X	2.375	.154	76	10'	1400'	2800'
2-1/2"	110253X	2.875	.203	120	10'	930'	1860'
3"	110303X	3.500	.216	157	10'	880'	1760'
3-1/2"	110353X	4.000	.226	189	10'	630'	1260'
4"	110403X	4.500	.237	222	10'	570'	1140'
5"	110503X	5.563	.258	299	10'	380'	760'
6"	110603X	6.625	.280	390	10'	260'	520'

NOTE: X = 1 FOR 10' CONDUIT, 2 FOR 20' CONDUIT

Sunlight Resistant